

John Heywood
Northern Ireland Electricity Networks Ltd
Unit 3,
21 Old Channel Road
Belfast
BT3 9DE

By Email Only: John.Heywood@nienetworks.co.uk

Date: 27 May 2022

Our Ref: NET/E/TH/519

Dear John,

Request for Extension of Time to Issue a Connection Offer for Connection Application at Riggid Hill Wind Farm, NIE Networks reference 22/01634 (“the Application”)

Thank you for your letter dated 29 April 2022 (the **Letter**) setting out the Application.

The Application

The Letter describes the relevant background¹ to the Application.

Reference is made to Condition 30 of NIE’s distribution licence (**the Licence**).²

Condition 30 (5) provides that (barring specified exceptions) NIE Networks is obliged to make an offer for connection to the distribution system *as soon as practicable* and (by operation of Condition 30 (6)(b)) *in any event* within *3 months* from receipt of a valid/completed application for connection to the distribution system.

Condition 30 (7) of the Licence allows NIE Networks to make an application to the UR³ for a consent to an extended Condition 30 (6)(b) period. The making of such an

¹ What follows is a summary of the Application. It is not intended to be a complete rehearsal. All parts of the Application have been considered in making the decision set out in this correspondence. Failure to mention parts of the Application should not be taken as representing any failure to have regard to those parts.

² [Microsoft Word - NIE Distribution Licence](#)

application does not change NIE Networks' obligation to make a connection offer as soon as *practicable*. Nor does the grant (by the UR) of any application made change the position. The primary obligation, recorded in Article 20 of the Electricity (NI) Order 1992 (the **Electricity Order**), is to offer a connection offer as soon as *practicable* remains.

The Application records that NIE Networks considers, having regard to the level of renewable projects either with planning permission or going through planning that two new clusters are justified in line with Chapter 7 of the NIE Networks Statement Charges for Connections.⁴

Rigged Hill Wind Farm (**RHWF**) joined the queue for *Cam Cluster* on 14 March 2022. This is the date from which time runs for the purposes of Condition 30 (5) of the Licence. That means that, without the consent of the UR under Condition 30 (7), NIE Networks is bound to offer terms for connection as soon as practicable and in any event by 14 June 2022.

The Application states that NIE Networks submitted a Section S application for *Cam Cluster*, an application SONI deemed valid on 24 December 2021. Discussions between NIE Networks and SONI regarding the location for *Cam Cluster* resulted in SONI asking the UR to consent to the extension of the period specified in Condition 25 of the SONI TSO Licence viz the making of a Section S offer to NIE Networks (for the Cam Cluster) from 26 March 2022 out to 30 May 2022.

The UR notes that SONI's application was granted by decision dated 25 March 2022 and published 5 April 2022.⁵

NIE Networks indicates in the Application that it cannot proceed to design the unique element of the (RHWF) connection until it is in receipt Section S offer for Cam Cluster; as SONI might not be able to provide an offer, or might change the proposed location of the cluster substation.

³ In this correspondence we use the words "us" "we" "our" "UR" "Utility Regulator" and "Authority" interchangeably to refer to the Northern Ireland Authority for Utility Regulation.

⁴ <https://www.nienetworks.co.uk/statementofcharges>

⁵ [SONI Condition 25 Extension to Connection Offer – Cam Cluster | Utility Regulator \(uregni.gov.uk\)](https://www.uregni.gov.uk/soni-condition-25-extension-to-connection-offer-cam-cluster)

The Application requests that the UR consent (pursuant to Condition 30(7) of the Licence) to the period under Condition 30(6)(b) of the Licence (in respect of DS WF's connection application) being extended from 14 June 2022 to **30 August 2022**.

This end date of 30 August 2022 is made up as follows:

(i) a period of 3 months out from the date (30 May 2022) by which NIE anticipates receiving the Section S offer for Cam Cluster from SONI

NIE Networks' rationale for the proposed extension (to the requisite C 30(5) period) is described as follows:

Extension Rationale

1. *To allow the efficient connection and to minimise the environmental impact of a number of renewable projects through the creation of a new cluster at Cam.*
2. *If an extension was not granted to allow NIE Networks to receive a section S offer from SONI, NIE Networks would then look to connect Rigged Hill to Garvagh Main, which would be 18km versus 6km to Cam Cluster.*
3. *Removing Rigged Hill from Cam Cluster would result in the chances of Cam Cluster not being fully subscribed.*
4. *Following discussions with [the developer of RHWF], it has been agreed that this application for an extension should progress until such time where NIE Networks knows the outcome of the Section S offer from SONI for Cam Cluster.*

The Application goes on to record the "impacts" of a decision on the proposed extension to the requisite Condition 30 period as follows:

Granting Extension - Impact Assessment

- *This extension would allow the applicant to remain in the connection queue for the 90MW at the proposed Cam Cluster where there is an opportunity for network capacity to become available that would facilitate the connection of this proposed project.*

- *This extension would facilitate a fair and transparent network capacity allocation and queuing process for the capacity available for the 90MW at Cam Cluster.*
- *Enabling this application to remain in the queue presents a potential benefit by providing a greater opportunity for the remaining capacity for the 90MW at Cam Cluster to be fully committed.*
- *This extension will enable NIE Networks to progress the connection design and production of a connection offer subject to capacity becoming available.*

Not Granting Extension- Impact Assessment

- *As capacity is not available at Limavady Main BSP and Coleraine Main BSP due to the transformers currently being fully subscribed, a connection would have to be offered from Garvagh Main S/S. This would result in a connection route of over 16km and has the potential to make the project economically unviable.*
- *A connection to Garvagh Main would result in reducing the chances of Cam Cluster becoming viable.*

Consultation associated with the Application

Condition 30(7)(a) of the Licence provides that NIE Networks must consult with the applicant for connection in respect of which the application under Condition 30(7) is made. In this case that is the applicant for connection of RHWF. The Application provides evidence of the requisite consultation.

We note that while the applicant (Scottish Power Renewables) are disappointed that they will not receive their offer until 30 August 2022 (at the latest), they do welcome the approach by NIE Networks that ensures their offer provides the full details of the works required following conclusion of the discussions between the TSO and NIE Networks. We also note that the applicant has requested a meeting with NIE Networks following the conclusion of their talks with the TSO to discuss the progress/outcome of the discussions. Finally, we note the applicant state that they anticipate their offer, once received, will still be subject to the full 90 days validity period for acceptance.

Condition 30(7)(a) of the Licence also provides that NIE Networks should consult with “such other persons as [NIE Networks] considers may be affected or interested” in the Application. We note that NIE Networks has engaged with SONI in determining if there is Transmission Capacity available for RHWF. We further note the confirmation of discussions with one other applicant in the queue for *Cam Cluster*. NIE Networks has

engaged with this particular applicant *viz.* delay and anticipates making a requisite C 30(7) application. NIE Networks highlights that there is no impact of RHWF on the other applicant, as if a Section S offer is received for *Cam Cluster* it will be capable of accommodating both projects.

The Authority's decision

Having considered the matter fully, the UR hereby confirms that it consents to the Application. It follows that the period under Condition 30(6)(b) of the Licence (in respect of the application for connection of RHWF) is now extended until **30 August 2022**.

We would take this opportunity to confirm that the period ending 30 August 2022 is a "long stop" date. The obligation under Condition 30 of the Licence is (now), subject to applicable exceptions⁶, to offer terms of connection for RHWF "as soon as practicable" and "in any event no later than" 30 August 2022. The Licence obligation is not (now) simply to offer connection terms by 30 August 2022.

This decision will be published in the normal way.

Please do return to us should you require any clarification.

Yours sincerely,



Tanya Hedley
Director of Networks

⁶ Consonant with NIE Networks' licence obligations and its statutory duties set out in Articles 12 and 19 of the Electricity Order.